




CNWPVC-RW

JANUARY, 2016

RECLAIMED WATER SDR-21 SOLVENT WELD 20' LENGTH 200 PSI PVC 1120 ASTM D2241 	SIZE	O.D.	I.D.	MIN. WALL	WEIGHT PER 100'	FEET PER PALLET	PERCENT OF TL	MIN. BELL LENGTH	PART NO.
	1/2**	.840	.716	.062	9.83	8400	2.5	2.000	57015
	3/4	1.050	.930	.060	12.14	6600	3.0	2.125	57030
	1	1.315	1.189	.063	16.20	5400	3.7	2.375	57045
	1 1/4	1.660	1.502	.079	25.65	4000	3.2	2.750	57055
	1 1/2	1.900	1.720	.090	33.39	3600	3.9	3.000	57070
	2	2.375	2.149	.113	52.43	2800	4.9	3.000	57085
	2 1/2	2.875	2.601	.137	76.69	2240	5.0	3.500	57100
	3	3.500	3.166	.167	113.71	1500	5.4	4.000	57110

*SDR 13.5 - 315 PSI

RECLAIMED WATER SCH 40 SOLVENT WELD 20' LENGTH PVC 1120 ASTM D1785 	SIZE	O.D.	I.D.	MIN. WALL	WEIGHT PER 100'	FEET PER PALLET	PERCENT OF TL	MIN. BELL LENGTH	PART NO.
	1/2**	.840	.622	.109	16.21	8400	2.5	2.000	57215
	3/4	1.050	.824	.113	21.62	6600	3.0	2.125	57230
	1	1.315	1.049	.133	32.07	5400	3.7	2.375	57245
	1 1/4	1.660	1.380	.140	43.49	4000	3.2	2.750	57255
	1 1/2	1.900	1.610	.145	51.94	3600	3.9	3.000	57270
	2	2.375	2.067	.154	69.85	2800	4.9	3.000	57285
	2 1/2	2.875	2.469	.203	110.80	2240	5.0	3.500	57300
	3	3.500	3.068	.216	144.82	1500	5.4	4.000	57310
	4	4.500	4.026	.237	206.63	580	3.6	4.000	57320
6	6.625	6.065	.280	364.12	400	5.6	6.000	57330	

RECLAIMED WATER SDR-21 GASKET JOINT 20' LENGTH 200 PSI PVC 1120 ASTM D2241 	SIZE	O.D.	I.D.	MIN. WALL	WEIGHT PER 100'	FEET PER PALLET	PERCENT OF TL	LENGTH	PART NO.
	3"	3.500	3.166	.167	116.92	1160	4.2	20'	57180
	4	4.500	4.072	.214	193.40	760	4.0	20'	57187
	6	6.625	5.993	.316	421.42	360	5.0	20'	57195
	8	8.625	7.805	.410	716.77	280	6.2	20'	57199

GASKET JOINT PIPE IS 20 FT. LAYING LENGTH ± 1" WITH INSERTION RING MARKED ON THE BEVELED SPIGOT END OF PIPE.

GASKET JOINT PIPE IS PRODUCED WITH AN INTEGRAL BELL END WITH A REINFORCED GASKET CONFORMING TO ASTM F477.