



PVC PURPLE
RECLAIMED WATER PIPE

CWPVC-9

JANUARY, 2016

| | SIZE | O.D. | I.D. | MIN. WALL | WEIGHT PER 100' | FEET PER PALLET | PALLETS PER T.L. | PART NO. |
|---|-------|-------|-------|-----------|-----------------|-----------------|------------------|----------|
| SDR-21 RECLAIMED WATER PIPE 200 PSI PVC1120 ASTM D2241 | ¾" | 1.050 | .930 | .060 | 12.12 | 6600 | 40 | 57030 |
| | 1 | 1.315 | 1.189 | .063 | 16.17 | 5400 | 32 | 57045 |
| | 1¼ | 1.660 | 1.502 | .079 | 25.60 | 4000 | 32 | 57055 |
| | 1½ | 1.900 | 1.720 | .090 | 33.32 | 3600 | 28 | 57070 |
| | 2 | 2.375 | 2.149 | .113 | 52.32 | 2800 | 24 | 57085 |
| | 2½ | 2.875 | 2.601 | .137 | 76.54 | 2240 | 20 | 57100 |
| | 3 | 3.500 | 3.166 | .167 | 113.72 | 1500 | 20 | 57110 |
| | 4 | 4.500 | 4.072 | .214 | 187.92 | 580 | 28 | 57120 |
| 6 | 6.625 | 5.993 | .316 | 408.24 | 400 | 20 | 57130 | |

| | | | | | | | | |
|--|-------|-------|-------|--------|--------|------|-------|-------|
| SDR-13.5 RECLAIMED WATER PIPE 315 PSI PVC1120 ASTM D2241 | ½" | .840 | .716 | .062 | 9.81 | 8400 | 44 | 57015 |
| | 2 | 2.375 | 2.023 | .176 | 78.80 | 2800 | 24 | 57425 |
| | 2½ | 2.875 | 2.449 | .213 | 113.50 | 2240 | 20 | 57435 |
| | 3 | 3.500 | 2.982 | .259 | 170.70 | 1500 | 20 | 57445 |
| 4 | 4.500 | 3.834 | .333 | 281.80 | 580 | 28 | 57455 | |

| | | | | | | | | |
|--|--------|--------|--------|---------|--------|------|-------|-------|
| SCH-40 RECLAIMED WATER PIPE PVC1120 ASTM D1785 | ½" | .840 | .622 | .109 | 16.25 | 8400 | 44 | 57215 |
| | ¾" | 1.050 | .824 | .113 | 21.67 | 6600 | 40 | 57230 |
| | 1 | 1.315 | 1.049 | .133 | 32.14 | 5400 | 32 | 57245 |
| | 1¼ | 1.660 | 1.380 | .140 | 43.58 | 4000 | 32 | 57255 |
| | 1½ | 1.900 | 1.610 | .145 | 52.05 | 3600 | 28 | 57270 |
| | 2 | 2.375 | 2.067 | .154 | 70.00 | 2800 | 24 | 57285 |
| | 2½ | 2.875 | 2.469 | .203 | 111.03 | 2240 | 20 | 57300 |
| | 3 | 3.500 | 3.068 | .216 | 145.43 | 1500 | 20 | 57310 |
| | 4 | 4.500 | 4.026 | .237 | 207.06 | 580 | 28 | 57320 |
| | 6 | 6.625 | 6.065 | .280 | 364.89 | 400 | 20 | 57330 |
| | 8 | 8.625 | 7.961 | .322 | 549.21 | 280 | 16 | 57340 |
| | 10** | 10.750 | 10.020 | .365 | 775.36 | 160 | 16 | 57350 |
| 12** | 12.750 | 11.938 | .406 | 1025.36 | 120 | 12 | 57360 | |

** NON-STOCK ITEM

| | | | | | | | | |
|--|------|--------|--------|------|---------|------|----|-------|
| SDR-21 GASKET JOINT RECLAIMED WATER PIPE 200 PSI PVC1120 ASTM D2241 | 3" | 3.500 | 3.166 | .167 | 117.16 | 1160 | 20 | 57180 |
| | 4 | 4.500 | 4.072 | .214 | 193.81 | 760 | 20 | 57187 |
| | 6 | 6.625 | 5.993 | .316 | 422.31 | 360 | 20 | 57195 |
| | 8 | 8.625 | 7.805 | .410 | 716.77 | 280 | 16 | 57199 |
| | 10** | 10.750 | 9.728 | .511 | 1113.20 | 160 | 16 | 57200 |
| | 12** | 12.750 | 11.538 | .606 | 1568.19 | 120 | 12 | 57201 |

** NON-STOCK ITEM

GASKET JOINT PIPE IS 20 FT. LAYING LENGTH ± 1" WITH INSERTION RING MARKED ON THE BEVELED SPIGOT END OF PIPE.

GASKET JOINT PIPE IS PRODUCED WITH AN INTEGRAL BELL END WITH A REINFORCED GASKET CONFORMING TO ASTM F477.

CRESLINE RECLAIMED WATER PIPE IS PURPLE IN COLOR.



CRESLINE - WEST, INC.

CORPORATE HEADQUARTERS: 600 CROSS POINTE BOULEVARD • EVANSVILLE, IN 47715 • TELEPHONE (812) 428-9300

PLANT: 3747 W. BUCKEYE ROAD • PHOENIX, AZ 85009 • TELEPHONE (602) 269-5161

WAREHOUSE: 1930 W. WHITESBRIDGE ROAD • FRESNO, CA 93706 • TELEPHONE (559) 486-1840